

Government of Andhra Pradesh

A.P. State Disaster Response and Fire Services Department

Annual Periodical Renewal Fire Certificate

From:

District Fire Officer
Andhra Pradesh, East Godavari

To:

The District Educational Officer,
Main Road, 2nd Floor Beside District
Library, Kakinada, East Godavari District.**File No: 7765/EG/DFO/2019, Date:25/05/2019****Occupancy NoC RC Number: 1308/A2/2012, Dt.31.05.2012**

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Non Multi Storeyed Building of **Bharathi Vidya Bhavan School, represented by ch.Sri Ranganadha, D.No.2-126/3, Namavaram(V), Rajamahendravaram(R)** - Regarding.

- Ref:
1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO:140 Home(Prison & Fire Services) Department, Dt.04-09-2015.
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.
 3. This Office NOC for Occupancy Rc No. 1308/A2/2012, Dt.31.05.2012, Dt.31/05/2012
 4. Renewal NOC For Occupancy 1308/A2/2012, Dt.31.05.2012, Dt.23/05/2018.
 5. Online Application for Renewal NOC of ch.Sri Ranganadha, D.No.2-126/3, Namavaram(V), Rajamahendravaram(R) - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 24/05/2019.

<< 0 >>

The Management of Bharathi Vidya Bhavan School, represented by ch.Sri Ranganadha, D.No.2-126/3, Namavaram(V), Rajamahendravaram(R) has requested to issue Annual Periodical Fire Certificate for period 2017-2018 duly remitting the Fire Precautionary fee for Rs.31100/- vide challan No. 31019963812019, Dated 02/05/2019 at CFMS Online, SBI Online cmfs.

Bharatiya Vidya Bhavan Residential Public School

1. This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate **ch.Sri Ranganadha D.No.2-126/3, Namavaram(V), Rajamahendravaram(R)**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.

2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

4. This Annual Periodical Renewal Fire Certificate is valid from 31/05/2019 to 30/05/2020.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

The following deficiencies are identified by the officers of the department and needs to be attended to by the management.



7765/EG/DF0/2019

Your Sincerely,

[Signature]
31/5/2019
District Fire Officer

Andhra Pradesh, East Godavari

[Signature]
Bharathi Vidya Bhavan

25.05.19

Copy to Management ch. Sri Ranganadha, Bharathi Vidya Bhavan School, Bharathi Vidya Bhavan School

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned